

Certificate of Product Approval

Ningbo Hotion Cable Co., Ltd

CERTIFICATE NUMBER	ISSUE	COMPANY ADDRESS
1874a/01	01	3rd and 4th Floor, Building 3, No. 337 Keyan Road, Jishigang Town, Haishu District, Ningbo City, Zhejiang Province, China

The named company is authorised to use the LPCB mark in association with the product(s) listed in this certificate having complied with the requirements of the standard(s) detailed below:

PRODUCTS	STANDARDS (see appendix for details)
Hotion Fire Resistant Multi-core Cables	BS 6387:2013 (Category CWZ) EN 50200:2015 (Class PH120) EN 61034-2:2005+A2:2020 EN 60754-1:2014
Fire Resistant Cables	

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd	Obada Piracha Senior Certification Manager	11 September 2025 Date of Issue
---------------------------	---	------------------------------------

11 September 2025 Date of First Issue
--



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

BRE Global, Bucknalls Lane, Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com



LPCB® is a registered trademark of the Building Research Establishment Ltd.

Appendix to Certificate No: 1874a/01

ISSUE
01

Ningbo Hotion Cable Co., Ltd

Product name		LPCB Ref. No.			
Hotion Fire Resistant Multi-core Cables		1874a/01			
Nominal csa of conductor (mm ²) See note 1	Core construction (excluding drain wire and earth)	BS6387	EN 50200	EN 61034-2	EN 60754-1
0.5	2, 3 & 4	CWZ	PH120	>60%	<0.5% HCl
0.75	2, 3 & 4	CWZ	PH120	>60%	<0.5% HCl
1.0	2, 3 & 4	CWZ	PH120	>60%	<0.5% HCl
1.5	2, 3 & 4	CWZ	PH120	>60%	<0.5% HCl
2.5	2, 3 & 4	CWZ	PH120	>60%	<0.5% HCl
4.0	2, 3 & 4	CWZ	PH120	>60%	<0.5% HCl
6.0	2, 3 & 4	CWZ	PH120	>60%	<0.5% HCl

Uo/U 300/500V

Notes:

- 1. Class 1 and class 5 conductors only.

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

Obada Piracha

Obada Piracha
Senior Certification Manager

11 September 2025
Date of Issue

11 September 2025
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com



LPCB® is a registered trademark of the Building Research Establishment Ltd.