

CERTIFICATE

Issued to:
Applicant:
Guangdong Mason Technologies Co., Ltd.
No.2, Industrial West #1 Road, Songshan Lake
High-tech Industrial Development Zone
523808 Dongguan Guangdong, China

Licensee:
Guangdong Mason Technologies Co., Ltd.
No.2, Industrial West #1 Road, Songshan Lake
High-tech Industrial Development Zone
523808 Dongguan Guangdong, China

Product : LED fixed luminaires
Trade name(s) : MASONLED
Type(s)/model(s) : MS-AABBCCDDDD-*****

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:

- a type test according to EN IEC 60598-1:2021, EN IEC 60598-1:2021/A11:2022 and EN IEC 60598-2-1:2021
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 4347898


DEKRA hereby grants the right to use the ENEC certification mark.

The ENEC certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the ENEC certification agreement.

This certificate is issued on 13 January 2026 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 35-169919 REV.1

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



Kreny Lin
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: LED fixed luminaires
Trade name(s)	: MASONLED
Type(s)/model(s)	: MS-AABBCCDDDD-*****
Rated voltage and rated frequency	: 220-240 V 50/60 Hz or 176-280 Vdc
Rated power	: 10-78 W
Class	: class I
Ta	: 50 °C
Degree of protection	: IP54 for MS-LL series, IP40 for MS-LA series
Maximum interconnect current	: 16 A
Additional information	: non-user replaceable LEDs

TESTS**Test requirements**

EN IEC 60598-1:2021
EN IEC 60598-1:2021/A11:2022
EN IEC 60598-2-1:2021

Test result

The test results are documented in DEKRA test file 4945775.50.

Additional information

Model/Type reference:

MS-AABBCCDDDD-*****

Note:

“AA” can be “LL” or “LA”, “LL” means Lichtline Lumora, “LA” means Lichtline ApexGlare;

“BB” can be 07, 10, 12, 15, 18, 20 or 24, which means length, 07=700 mm, 10=1000 mm, 12=1200 mm, 15=1500 mm, 18=1800 mm, 20=2000 mm, 24=2400 mm;

“CC” can be 10-78, which means wattage, for example: 10=10 W, 11=11 W, 12 = 12 W, 78=78 W;

“DDDD” means CCT from 1800 K to 6500 K, for example: 18=1800 K, 20=2000 K, 27=2700 K, 65=6500 K, 4065=4000-6500 K;

“*****” means function code, “L” means phase line, “G” means adjust power, “S” means adjust CCT, “D” means DALI, “2” means 2836 LED, “3” means 3030 LED

This certificate replaces certificate No. 35-169919 which we hereby declare invalid.

The list of components is laid down in test report 4945775.50.

Conclusion

The examination has confirmed that all requirements were met.

Factory location

Guangdong Mason Technologies Co., Ltd.

No.2, Industrial West #1 Road, Songshan Lake High-tech Industrial Development Zone

523808 Dongguan Guangdong, China

Trade name : MASONLED stands for

