

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-24-04-10-01

Products: Wood flooring (multilayer) with different wood species in the top layer,
UV-lacquered with Eucalyptus plywood core and Birch back layer
Dimensions: length (600-4500) mm x width (50-450) mm x thickness (9-22) mm

Producer: Huzhou Teya Floor Co., Ltd.
No. 2-4 Qiangyuan Road, Xunbei Village
Nanxun Economic Development Zone
Huzhou, Zhejiang
313009 China

Order: Testing of selected properties according to EN 14342:2013 for CE-labelling

Test report: 2708003/300

Test results: *The above mentioned wood flooring can be classified regarding
to both properties according to EN 14342:2013 (CE-labelling) as follows:*

Property	Result	Declaration according to EN 14342:2013
Formaldehyde emission according to EN 717-1:2004:10	< LOD (144 h)	Class E1
Content of PCP according to CEN/TR 14823:2004	< LOQ	PCP $\leq 5 \times 10^{-6n}$

LOD = Limit of Detection

LOQ = Limit of Quantitation

Dresden, 10/04/2024



Head of laboratory

Engineer in charge